



Interoffice Memorandum

TO: Community Services Division, LDFR.

FROM: Captain Skulski (SS)

DATE: August 16, 2001

SUBJECT: NFPA 13D Sprinkler Systems in 3 Peaks

CC: Bill Linfield, Gene Emore, Jeff Berino, Mike Brake, Three Peaks Lot Owners and General Contractors.

I had conversation with Mr. Linfield, on this date, regarding the design of the sprinkler systems for the single family residences (SFR) in Three Peaks. He is aware of the design challenges for sprinkler systems posed by the 1" water taps. Mr. Linfield advised that the Town of Silverthorne will allow the up-sizing of the water line from the curb stop to the SFR. This change will reduce the significant friction loss experienced with the existing 1" water lines. It is recommended that the waterline be up-sized to 1 1/2".